

Resource Adequacy and the Energy Transition in the Pacific Northwest

Technical Appendix

April 2026



Energy+Environmental Economics

Arne Olson, Senior Partner
Aaron Burdick, Senior Director
Charles Li, Associate Director
Angineh Zohrabian, Managing Consultant
Bill Wheatle, Managing Consultant
Pedro de Vasconcellos Oporto, Sr. Consultant
Hugh Somerset, Sr. Consultant
Anna Jacobson, Consultant

Technical Appendix Content

+ Regional Trends and Challenges

+ Resource Adequacy Analysis

- RECAP Methodology
- Inputs & Assumptions
- Subregional Results

+ Portfolio Optimization Analysis


- RESOLVE Methodology
- Inputs & Assumptions
- Detailed Portfolio Analysis Results
- Renewable Land Use

+ Long-term (2045) System Reliability Dynamics

Regional Trends and Challenges



Since 2017, NW regional studies have changed from indicating future RA deficits to immediate reliability risk with a growing resource gap



2021-2024 Extreme Summer Peak Events


- + The region experienced an historical extreme heat event in history in June 2021
- + Each summer since then (2022, 2023, 2024) has continued to show extreme heat and peak demand near the 2021 peak of ~33,000 MW
 - o 2020-2022 all experienced summer peaks near or above winter peaks

Climate.gov Home

Astounding heat obliterates all-time records across the Pacific Northwest and Western Canada in June 2021

One of, if not the, worst heat wave in the region's modern records impacted the Pacific Northwest of the United States and western Canada...

Jun 30, 2021



The Guardian


Record-breaking US Pacific north-west heatwave killed almost 200 people

Officials reported 116 deaths in Oregon and 78 in Washington after extreme temperatures in normally moderate region.

Jul 8, 2021



NWPCC region loads




Annual energy and winter peak loads were flat for many years, but are starting to pick up

Summer peaks are more consistently growing



Winter and summer peaks hit records in 2024

Summer peak loads and regional temperatures




January 2024 Cold Snap Event

Pacific Northwest Operations, MW



Over half of imports were from outside the Greater NW region (via CA transmission)

Hydro Fleet Utilization, % of maximum 2024 output



“The amount of inter-regional support necessary to manage... operations through the cold weather event is **indicative of the pressing need to address RA and potential capacity shortfalls as soon as practicable**, highlighting the value of an RA program with a broad geographic footprint and diversity of load and resources.” – Western Power Pool [Jan 2024 Event Assessment](#)

Challenges remain to addressing regional RA needs

- + Since E3's previous Pacific NW studies (2017 and 2019) highlighted a multi-GW growing regional shortfall, resource adequacy concerns in the region remain, driven by:
1. Changing climate patterns and extreme events have stress-tested the system more than ever before in cold-snap and heat-wave events
 2. Faster than-expected electrification and data center load growth continue to increase load forecasts
 3. Not enough new resources have been built to fill the previously identified gap

Prior Recommendation	Status	Summary
Develop formal mechanism for regional sharing of planning reserves	Delay	WRAP was established in 2022 to support regional RA sharing and is now just on the verge of becoming operational. To date it was not designed to provide long-term accreditation forecasts that would allow market participants to conduct adequate forecasting, though there are discussions to consider doing so.
Ensure sufficient firm generation to maintain system reliability as coal retires and load grows	Set-back	Natural gas is the only near-term commercialized firm resource option. OR has a ban on new gas capacity, new gas in WA is expected to face siting and permitting challenges and may require pipeline expansion, creating a challenge for new firm capacity in the most RA constrained areas. Outside OR/WA, several planned coal retirements will now be coal-to-gas conversions, and some new gas has been built in MT/UT/ID/WY.
Maintain existing clean energy infrastructure	Under threat	Existing hydro and nuclear fleet have been maintained, though there is ongoing advocacy for some hydro dam removal.
Build clean energy resources at a fast pace to meet decarbonization targets and growing energy needs	Critical	IRPs identified 35+ GW of new resources between 2018-2032 (nearly all renewable or short-duration energy storage), annual capacity additions would need to rapidly increase to stay on that path while new growth faces key constraints incl. limited firm transmission

Resource Adequacy Analysis

RECAP Methodology, Inputs & Assumptions, Subregional Results




Energy+Environmental Economics

Three Key Steps for Reliability Planning

Part 1: Model + Data Development

Develop a robust dataset of the loads and resources, typically in a loss of load probability (LOLP) model

LOLP modeling evaluates resource adequacy across all hours of the year under a broad range of weather conditions




Robust probabilistic models + datasets are the foundation of any resource adequacy analysis

Part 2: Need Determination

Identify the Total Reliability Need to achieve the desired level of reliability

Factors that impact the amount of effective capacity needed include load & weather variability, operating reserve needs




The total reliability need is calculated to meet a target reliability standard (e.g. 0.1 LOLE)

Part 3: Resource Accreditation

Calculate resource capacity contributions

Measures a resource's contribution to reliability needs relative to target reliability, accounting for performance across all hours



Resource accreditation determines how much each resource counts towards the total reliability need

E3's RECAP loss-of-load probability model was used to study resource adequacy needs and resource contributions

+ RECAP is a loss-of-load-probability model developed by E3 to study the reliability dynamics of high-renewable electricity systems

+ RECAP simulates the operations of the electricity system under thousands of scenarios to capture different conditions

- Including load variability, weather variability, renewable output variable, forced outage events,

+ Key RECAP outputs:

- System reliability
- Target Planning Reserve Margin
- Capacity Shortfall
- Capacity Value of Resources

Temperature and Load Artificial Neural Network Simulation

Capturing hourly load conditions under mild and extreme historical weather



Operational Module

Dispatching resources based on outage characteristics, weather dependency, state of charge availability, and demand-side management



System Reliability: simulates the operations of the electricity system under thousands of scenarios to capture different conditions

Load



Solar




Wind




1,000s
× weather
years

Resource Capacity Value: measures resource's ability to contribute to reliability under a marginal or average ELCC methodology

Illustrative ELCC Values Across Technologies




The entire northwest system is modeled in this study with subregional representation to capture local resource adequacy challenges



- + In this study, we define the study area as the following three regions within what we call the “Greater Northwest”:
 - **Pacific NW subregion** includes most of the participating utilities and is the main WRAP MIDC Subregion, with transmission constraints between 4 subregions
 - **Inland NW subregion** includes NorthWestern Energy, which is also in WRAP MIDC
 - **Central West subregion** includes Idaho Power and PacifiCorp East, and is in the WRAP SWEDE subregion
- + **Resource adequacy assessments were performed on:**
 - Greater NW
 - Pacific NW subregion (OR + WA)
 - West of Cascades subregion (PNW_NW + PNW_SW)

Analysis captures the sharing of the resource adequacy capacity across the study regions and to/from neighboring regions



+ Firm import assumptions from outside the Greater Northwest

- British Columbia: 1,250 MW in the Summer, into the **Pacific Northwest subregion**
- Nevada and Rocky Mountains: 1,250 MW in the Winter, into the **Central West subregion**
- California: 2,500 MW in the Winter, into the **Pacific Northwest subregion**

+ Transmission availability within Greater Northwest – for sub-regional RA

- 4,600 MW from Inland NW and Central West into Pacific Northwest
- 19,250 MW from East to West of Cascades (PNW-NE and PNW-SE into PNW-NW and PNW-SW)

+ Firm export obligations at 660 MW of capacity are included to British Columbia based on the Columbia River Treaty Regime

Existing and planned resources in the Northwest

+ E3’s near-term resource adequacy analysis assessment includes existing and high-likelihood planned resources in the Greater Northwest study footprint 2025-2030

- For long-term analysis, E3 uses RESOLVE to optimize resource builds across the Greater NW footprint. Outside of the Greater NW, RESOLVE dispatches a representative future portfolio of WECC resources.


+ Baseline list of existing and planned resources taken from the WECC 2034 Anchor Data Set (ADS)

- Only high-likelihood planned projects were retained
 - Projects with specific siting and selected developer were retained
 - Generic resource additions were removed
- Minor data quality adjustments made (e.g., correct assignment of resource to subregion, double counted planned projects)

+ Near-term plans were adjusted to reflect latest public announcements and contract information

- Review of most recent IRPs, BPA 2024 White Book, and news presses
- Coal plans based on PacifiCorp’s 2025 IRP Draft, Northwestern’s 2023 IRP, & Northwestern acquisition of Colstrip

Existing and In-Development Resources
Installed Capacity, MW



■ Demand Response	1,122	1,122	1,122	1,122	1,122	1,122
■ Battery Storage	-	1,058	1,098	1,137	1,137	1,292
■ Solar	6,742	8,031	8,210	8,263	8,263	8,263
■ Wind	13,630	14,444	14,904	14,904	14,822	14,912
■ Hydro	34,451	34,722	34,696	34,785	34,785	34,792
■ Other	678	672	662	662	581	581
■ Gas	14,705	14,824	14,913	15,026	15,231	15,591
■ Coal	7,390	6,280	6,050	6,050	5,823	5,463
■ Nuclear	1,169	1,169	1,169	1,169	1,169	1,169


Near-term demand growth in the Greater Northwest is ~3%/yr, driven by data centers and electrification

+ Load growth projections for the Greater Northwest were developed based on E3’s in-house PATHWAYS model in alignment with economic trends by sector and projected growth driven by state energy policies

- This forecast accounts for recent federal policy changes, such as the revocation of ACC II and ACT
- Annual energy demand is projected to grow by 3%/yr across the Greater Northwest region, which is in line with the 3.2%/yr growth seen in PNUCC’s 2025 Load Forecast (note: these correspond to slightly different geographies)

Load Growth Projection, Reference Scenario

Annual aMW




	2025		2030	
	aMW	Peak MW	aMW	Peak MW
Greater Northwest	31,900	45,300	36,700	52,400
Pacific Northwest	21,500	30,900	24,500	35,600
West of Cascades	14,200	20,900	16,100	24,300

Regional Reference Load Forecasts

Greater Northwest


Greater Northwest

Reference Load Forecast (GW)



- + Between 2025-2035 summer and winter peak loads grow by 2.7%/yr and 3.2%/yr, respectively, due to data electrification and center load growth
- + Seasonal peaks gradually diverge as heating electrification accelerates

44.0	50.8	58.0	65.6	72.7	Winter Peak Coincident, GW
44.4	50.5	56.3	62.5	69.1	Summer Peak Coincident, GW
31.9	36.7	40.4	44.2	47.9	Annual Load aGW




Regional Reference Load Forecasts

Pacific Northwest


Pacific Northwest

Reference Load Forecast (GW)



Year	2025	2030	2035	2040	2045	
Winter Peak Coincident, GW	30.8	35.6	40.8	46.5	51.9	Winter Peak Coincident, GW
Summer Peak Coincident, GW	29.2	33.4	37.4	42.2	47.2	Summer Peak Coincident, GW
Annual Load aGW	21.5	24.5	27.1	29.9	32.5	Annual Load aGW

- + Between 2025-2035 summer and winter peak loads grow by 2.8%/yr and 3.2%/yr, respectively, due to data electrification and center load growth
- + Seasonal peaks gradually diverge as heating electrification accelerates




Regional Reference Load Forecasts

West of Cascades


West of Cascades

Reference Load Forecast (GW)



Year	2025	2030	2035	2040	2045	Category
20.9	24.3	27.8	31.7	35.4	Winter Peak Coincident, GW	
19.2	21.9	24.7	27.8	31.1	Summer Peak Coincident, GW	
14.2	16.1	17.9	21.5	23.1	Annual Load aGW	


- + Between 2025-2035 summer and winter peak loads grow by 2.8%/yr and 3.3%/yr, respectively, due to data electrification and center load growth
- + Seasonal peaks gradually diverge as heating electrification accelerates




Hydro Modeling Approach

- + The 2018 RA study used 1929-2008 hydro conditions
- + After consulting with BPA, this current study uses BPA's recent past 30-year generation profiles reflective of current weather patterns, downscaling them to weekly resolution
 - Aligns with BPA's current near-term resource planning methods
 - Avoids anomalous low hydro water conditions in 1930s and 1940s not representative of current expected precipitation patterns
- + These profiles capture the seasonal variability of hydro, as well as the distribution of annual hydro output across decades of weather years
 - Hydro operations are modeled using weekly budgets with 5% of inter-week budget sharing, reflecting the flexibility observed in real-world hydro operations
- + The analysis uses 7 years of hourly hydro generation (2018-2024) to characterize the minimum and maximum power constraints on output by season based on weekly hydro availability
 - Pmin values fit to historical 1-hour limits
 - Pmax values fit to historical 4-hour limits¹

Weekly Budget for Pacific NW Hydro, 2006




Winter Operational Data for Pacific NW Hydro




Hydro Hourly Dispatch Limits


Winter




Spring



Summer




Fall




Hydro Energy Variability

Annual Hydro Energy over 30 years - BPA's 2024 White Book



Monthly Hydro Energy Variability in PNW




Hydro Energy (aMW)	Median Year	1-in-10 Low Year	Variability
Annual	14,076	12,175	-13.5%
Critical Winter Months <i>Dec - Feb</i>	15,595	12,201	-21.8%

Monthly Hydro Energy Variability


Year	Month	Monthly Hydro Output (aMW)	vs. Monthly Average
1993	February	9,655	-39%
1989	February	10,619	-33%
2004	February	11,402	-28%
1992	December	11,404	-21%
2010	February	11,517	-27%
1993	January	11,600	-29%
1994	February	11,609	-26%
2001	January	11,643	-29%
2001	February	11,662	-26%
1993	December	11,708	-19%

Average	December	14,478
	January	16,408
	February	15,781



1989–2018 Winter Months (Dec-Feb)
Monthly Hydro Generation (aMW)

Updated 30-year Hydro Dataset vs. Prior 80-Year Dataset




	Median Annual aMW	Median Winter aMW	1-in-10 Annual aMW	1-in-10 Winter aMW
80-year	14,191	14,457	11,092	10,682
30-year	14,076	15,595	12,201	12,175
<i>Change</i>	<i>-1%</i>	<i>+8%</i>	<i>+10%</i>	<i>+14%</i>

Decreased winter low hydro extremes in 30 year vs. 80 year dataset
 → net increase in hydro RA contributions

Hydro Budgets and Weekly Energy Shifting

- + **E3 incorporated 5% of hydro flexibility across different weeks to allow the most constrained periods to get some additional hydro energy beyond the average for that month**
 - This additional energy a week can use still needs to be dispatched within the Pmax hourly operational constraints already set for the given season and hydro budget
 - A week's hydro budget can be reduced by 5% to support an adjacent week while still maintaining its dispatch above its Pmin hourly operational constraints

Weekly Budgets for 2002 Hydro Year – PNW-NE




Hydro weekly shifting faces additional practical constraints:

- **Foresight limitations:** uncertain load conditions 1-2 weeks out
- **Market opportunity costs:** withholding hydro capacity for uncertain futures market prices
- **Biological and river flow constraints:** impact Pmin volumes that limit holding back water


How to define reliability in a hydro-heavy system?

- + In capacity-constrained systems, **reliability is typically defined though one day in ten years loss-of-load expectation, or 0.1 LOLE**, which usually corresponds to infrequent and short loss-of-load events across plausible weather conditions
- + In a hydro dominated system with energy shortfall risk, **the typical 0.1 LOLE standard can be met even when events are severe and last entire days**, and thus **could be considered not stringent enough** relative to what is considered reliable in other systems
 - A hydro dominated system which needs to stay below an equivalent amount of unserved energy as a capacity-constrained system is, on the other hand, too constrained
- + **For this study, the reliability criteria for calculating system resource needs and ELCCs was set based on the equivalent normalized expected unserved energy (NEUE) of today's system at 0.1 LOLE**
 - This maintained a consistent metric as the system evolves in future years with increased peak loads and energy-limited resource additions.

Equivalence Between RA Metrics
Normalized Expected Unserved Energy
 (% of annual load/year)
 vs.
Loss-of-load Expectation
 (days/year)



The Pacific Northwest subregion faces a local supply deficit in 2026 which grows to 5,000 MW of effective capacity by 2030



+ Load growth and retirements mean the region faces a power supply shortfall in 2026

+ The region currently relies on 5,750 MW of imports to maintain reliability

+ Nearly 5,000 MW of new effective capacity is needed by 2030

+ Projects currently in active development account for only 2,300 MW of new effective capacity

+ 1,000 MW from new firm import capacity (B2H)

+ 340 MW from hydro upgrades

Pacific Northwest Subregion Load and Resource Balance
Effective Capacity (ELCC) MW


System Needs (ELCC MW)	2025	2026	2027	2028	2029	2030
Total Resource Need*	35,309	36,441	37,717	38,922	40,066	40,846
Existing Portfolio w/ Retirements	29,581	28,890	28,826	28,820	28,743	28,738
Existing Firm Imports	7,100	7,100	7,100	7,100	7,100	7,100
Reliability Position Surplus (+) / Shortfall (-)	+1,373	-451	-1,791	-3,002	-4,224	-5,008
New Firm Import Capacity**	-	-	-	1,000	1,000	1,000
ELCC from “In-Development”*** Hydro Upgrades	-	244	244	335	335	335
ELCC from “In-Development” Wind, Solar and Battery projects	-	86	350	541	966	996

* Total Resource Need includes peak load + planning reserve margin as well as obligation to serve the Columbia River Treaty Regime

** Firm Import Capacity into the PNW subregion increases with new transmission from within the Greater Northwest as long as the broader region remains reliable overall

*** In-development resources are WECC ADS 2034 facilities with confirmed project location, project name, and can be verified online

The West of Cascades subregion rapidly trends towards a local supply deficit by ~2030



+ Load growth and retirements mean the subregion might face a local supply deficit in the near term

+ The subregion currently relies on 14,500 MW of imports to maintain reliability, which are only available if the broader Pacific Northwest subregion is reliable

+ Projects currently in active development account for only 1,900 MW of new effective capacity

+ 1,500 MW from new firm import capacity

West of Cascades Subregion Load and Resource Balance
Effective Capacity (ELCC) MW

System Needs (MW)	2025	2026	2027	2028	2029	2030
Total Resource Need*	24,525	25,240	26,047	26,796	27,527	28,016
Existing Portfolio w/ Retirements	10,057	9,309	9,216	9,163	9,051	9,030
Existing Firm Imports	19,250	19,250	19,250	19,250	19,250	19,250
Reliability Position Surplus (+) / Shortfall (-)	+4,782	+3,319	+2,419	+1,617	+774	+264
New Firm Import Capacity**	-	-	-	-	-	1,500
ELCC from “In-Development”*** Firm Resources	-	153	153	205	205	205
ELCC from “In-Development” Wind, Solar and Battery projects	-	168	168	168	168	168

* Total Resource Need includes peak load + planning reserve margin as well as obligation to serve the Columbia River Treaty Regime

** Firm Import Capacity into the WOC subregion increases with new transmission from within the Pacific Northwest as long as that subregion as well as the broader Greater Northwest region remain reliable overall

*** In-development resources are WECC ADS 2034 facilities with confirmed project location, project name, and can be verified online

Portfolio Analysis

RESOLVE Methodology, Inputs & Assumptions, Detailed Portfolio Results




Energy+Environmental Economics


E3's RESOLVE optimal capacity expansion model was used to study long-term portfolio optimization

- + RESOLVE is a linear optimization model tailored to study electricity systems with high renewable & clean energy policy goals
- + Optimization balances fixed costs of new investments with variable costs of system operations, identifying a least-cost portfolio of resources to meet needs across a long-time horizon
- + Has been used to study low-carbon portfolios in California, Pacific Northwest, Hawaii, New York, and other places


Operational module simulates hourly system operations for a sample of representative days



Reliability module ensures portfolio can meet load during extreme conditions using an ELCC approach



Least-cost plan co-optimizes investments and operations to meet clean energy policy targets, selecting from a diverse set of potential resources including wind, solar, storage, DSM, and natural gas




Example RESOLVE result from *Long-Run Resource Adequacy under Deep Decarbonization Pathways for California* (Calpine, 2019)

Modeled greenhouse gas (GHG) trajectories

- + GHG emissions reductions are relative to 1990 emissions of 60 MMT¹
- + GHG emissions in 2025 are benchmarked to statewide historical emissions
- + Emission trajectories between 2025 and 2045 are linear
- + GHG emissions target is applied to the entire GNW region in RESOLVE

Greater Northwest Reference Emissions and Modeled Greenhouse Gas Targets



Regional Load Forecasts

Electrification Scenarios


Category	Reference	High Loads
Policy	Assumes rollback of all federal policy finalized under the Biden administration and state transportation policy	Includes all finalized state policies and all federal policies finalized under the Biden administration Includes additional state targets to achieve net-zero emissions in the Greater Northwest
Space Heating Electrification	Heat pump market share increases based on historical trends from AHRI and state electrification programs	All-electric heat pump market share increases to 100% of new sales by 2040
Transportation Electrification	Passenger and freight vehicle electrification consistent with current ZEV market trends	ZEV sales reach 100% by 2035 for passenger vehicles, 100% by 2040 for freight vehicles
Energy Efficiency and Other Sources	Levels consistent with state policy and market trends	Increased efficiency and electrification consistent with net-zero emissions, including building shell upgrades and industrial efficiency
Data Centers	3.1 aGW of new data center load by 2045	
Climate Change	Annual changes in Cooling and Heating Degree-Days from EIA's Annual Energy Outlook	

Regional Load Forecasts

Incremental Load Growth by Sector

Reference Loads


Incremental Load Growth by Sector over Baseline (aMW)



Annual Load by Sector aMW	2025	2030	2035	2040	2045
Baseline	31,916	31,916	31,916	31,916	31,916
Industry	-	681	900	1,129	1,367
Commercial	-	762	1,663	2,748	3,943
Residential	-	558	1,176	1,814	2,449
Transportation	-	895	2,273	3,787	5,129
Data Centers	-	1,862	2,438	2,800	3,105

High Loads

Incremental Load Growth by Sector over Baseline (aMW)




Annual Load by Sector aMW	2025	2030	2035	2040	2045
Industry	-	1,545	3,139	5,064	6,950
Commercial	-	681	1,548	2,754	4,125
Residential	-	446	1,024	1,850	2,818
Transportation	-	990	3,383	6,850	10,386
Data Centers	-	1,864	2,441	2,800	3,103

Regional Load Forecasts

Growth in Total Resource Need

Total Resource Need

All Regions and Scenarios, MW



+ Through 2035, EV adoption and new data centers contribute the most to growth in reliability needs

+ **Reference:** After 2035, residential space heating also drives some reliability need

+ **High Load:** After 2035, accelerated electrification across both buildings and transportation drive growth in reliability need

	2025	2030	2035	2040	2045	
GNW	49.2 (+0)	57.2 (+8.0)	69.0 (+19.8)	84.9 (+35.7)	103.0 (+53.8)	High Load Total Resource Need GW (+GW Increase Relative to 2025)
PNW	35.3 (+0)	40.8 (+5.5)	48.6 (+13.6)	58.0 (+22.7)	67.1 (+31.8)	High Load Total Resource Need GW (+GW Increase Relative to 2025)
WoC	24.5 (+0)	28.0 (+3.5)	33.4 (+8.9)	39.8 (+15.3)	45.7 (+21.2)	High Load Total Resource Need GW (+GW Increase Relative to 2025)

Candidate Resources


Mature and Emerging Technology Resource Options Studied

Scenario		RA contributions	Additional considerations
Mature	Solar	Low and declining ELCCs	Variable energy resource
	Onshore wind	Declining ELCCs	Variable energy resource
	Natural gas	Firm	Carbon emitting, requires pipeline infrastructure
	Short-duration storage (4-8 hr li-ion)	Declining ELCCs	ELCC saturation impacted by hydro fleet interactions
	Long duration storage (10-12 hr pumped hydro)	Declining ELCCs	ELCC saturation impacted by hydro fleet interactions
	Geothermal	Limited potential	High cost per kWh and limited PacNW sites
	Energy efficiency (embedded in load forecast)	High, but takes time to scale	Can reduce new load but cannot serve existing load
	Demand response	Declining ELCCs	Duration and use limited
Emerging	Natural gas to clean CT retrofits (H2, RNG, etc.)	Firm	High enabling infrastructure costs + long timelines
	New clean CTs (H2, RNG, etc.)	Firm	High enabling infrastructure costs + long timelines
	Gas w/ 100% carbon capture and storage	Firm	High enabling infrastructure costs + long timelines
	Nuclear small modular reactors	Firm	Uncertain costs + long timelines
	Enhanced geothermal	Firm	Uncertain costs and potential
	Multi-day storage (100 hr)	Slower declining ELCCs	Uncertain costs, high round-trip energy losses

Candidate Resources

Renewable Resource Potential

- + The total resource potential, resource quality, and development costs of each renewable technology type are differentiated both between RESOLVE zones and within each zone¹




1. Zonal resource potential derived from by WestTEC PLEXOS capacity expansion study, which developed land use screens from [Wu et al \(2023\)](#). Screens remove legally protected, administratively protected, and high conservation value areas. Each zone includes tranches of wind and solar resources with distinct generation profiles, capacity factors, and interconnection costs

Candidate Resources


Renewable and Storage Resource Costs

- + Levelized candidate resource costs developed in RECOST, E3's in-house discounted cash flow model
- + Cost trajectories reflect market and policy outlook today, including sunseting of tax credits and supply chain bottlenecks
 - Supply chain bottleneck costs remain high in 2030, decline over across the decade
 - Solar and wind do not receive ITC/PTC, battery storage receives ITC until 2040


Candidate Solar
LCOE 2024\$/MWh



Candidate Wind
LCOE 2024\$/MWh



Candidate 4-hr Battery Storage
Levelized Fixed Cost 2024\$/kW-year




Candidate Resources

Renewable Resource Supply Curve

- + Greater Northwest renewable supply curve combines cost of resource development and interconnection
- + Resources in each region face rising tiers of interconnection costs once grid-proximate resources are selected

Greater Northwest Renewable Supply Curve

Levelized Cost of Energy and Interconnection Costs 2024\$/MWh | 2030




Candidate Resources

Renewable Resource Supply Curve

- + The Pacific Northwest has solar potential of varied quality across Washington and Oregon
- + All wind resource potential is located East of the Cascades

Pacific Northwest Renewable Supply Curve

Levelized Cost of Energy and Interconnection Costs 2024\$/MWh | 2030



Candidate Resources


Firm Resources – New Gas Generation

+ New Gas Generation is available to RESOLVE starting in 2030

- Elevated plant capital costs in 2030: \$2,800/kW for Combined Cycle, \$2,500/kW for Combustion Turbine
- Costs decline throughout 2030's as supply chain constraints & order backlog are relieved
- Firm gas delivery contract costs for new pipeline capacity are included within capital costs of new gas plants in the Greater Northwest region¹


Gas Plant Capital Cost Trajectory

2024\$/kW by Commercial Operating Date (COD)



Gas Annualized Fixed Cost Components

2024\$/kW-year for 2030 COD



1. Firm fuel delivery cost is estimated gas delivery contract cost of new pipeline in Greater Northwest region. New plants are assumed to hold firm delivery contract to generate at full plant capacity throughout winter season, with \$1.10/Dth/day incremental cost above non-firm delivery on existing pipelines.

Candidate Resources

If available, emerging technologies can provide “clean firm” capacity

+ Emerging technology cost and commercialization trajectories remain unknown

- Modeled to be available at scale by 2040


+ By providing “clean firm” capacity, emerging technologies may be able to reduce the costs and increase the feasibility to achieve up to 100% decarbonization of the NW system

Roles	Emerging Candidate Options	Capacity Provision	Energy Provision
Long-duration Energy Storage	12-hr Storage (eg. Vanadium Flow)	Subject to ELCC declines	None
	24-hr Storage (eg. Vanadium Flow, Thermal)		
	100-hr Storage (eg. Iron-Air)		
Clean Firm Baseload	Near-Field Enhanced Geothermal	Firm	High Likely to operate at moderate to high capacity factor
	Deep-Field Enhanced Geothermal		
	Nuclear SMR		
	New CCS		
Clean Combustion	Carbon-neutral fuels (eg. RNG, Green H2)	Firm	Low Likely to operate at low capacity factor due to high variable cost

Candidate Resources

Emerging Technology Options

Greater Northwest Resource Cost Comparison, 2045



+ Emerging Technologies are made available at scale after 2040

- Energy storage resources do not provide any energy value, but can be competitive capacity options long-term in cases with large renewable buildout
- Emerging new firm baseload generation can provide both energy and capacity at competitive costs
- Converting combustion turbines to run on clean fuels becomes the cheapest clean capacity resource but are expensive to run for energy

+ Low Cost sensitivity has 30% lower capital costs for Emerging Technologies

1. Figures show average costs of grid-proximate resources in Greater Northwest. Remote solar and wind resources are 30-60% more expensive due to interconnection costs.

2. Levelized Cost of Energy based on maximum potential generation of each resource type. Levelized Cost of Capacity based on estimated Greater Northwest resource marginal ELCCs in 2045: 93-95% for thermal, 8% for solar, 18% for wind, 12% for 4-hr Li-ion, 80% for 100-hr Iron-Air Battery. LCOE does not reflect energy arbitrage value of storage which is impacted by duration and round-trip efficiency losses.

Detailed Portfolio Analysis Scenarios and Results



Energy+Environmental Economics


Portfolio optimization scenarios consider GHG policy, loads, and technology availability

Policy Scenario	Load Scenario	Technology Scenario
No GHG Policy	Reference High Loads	Mature Technologies
62% GHG Reduction (below 1990 levels)	Reference High Loads	Mature Technologies
85% GHG Reduction	Reference High Loads	Mature Technologies
92% GHG Reduction	Reference High Loads	Mature Technologies
96% GHG Reduction (Current Policy Targets)	Reference	Mature Technologies Mature Technologies (No New Gas)
	High Loads	Mature Technologies Mature Technologies (No New Gas) Emerging Technologies (Long-Duration Storage) Emerging Technologies (Clean Baseload) Emerging Technologies (Clean Fuels) Emerging Technologies (No Combustion) Emerging Technologies (All) Emerging Technologies (All, Low Cost)
100% GHG Reduction	High Loads	Mature Technologies Emerging Technologies (Long-Duration Storage) Emerging Technologies (Clean Baseload) Emerging Technologies (Clean Fuels) Emerging Technologies (No Combustion) Emerging Technologies (All)

2035 Portfolio: Wind and solar scale to support clean energy policies, natural gas selected as least-cost RA resource

Greater Northwest

Installed Capacity in 2025 & 2035



+ To meet GHG reduction targets, all existing coal is retired by 2045

+ Renewables are added by 2035 to meet growing loads on the path to 2045 96% GHG Reduction decarbonization goals

- 13-26 GW Wind
- 3-13 GW Solar

+ For growing resource adequacy need, 6-16 GW natural gas are selected¹

- Renewables added for clean energy policies partially reduce the need for natural gas to the extent they generate during low hydro winter periods


+ Without new gas, costs and resource needs increase significantly

- Up to 77 GW storage and 4 GW DR are selected although ELCCs continue to be low

2045 Portfolio: Further load growth dramatically increases need for both new clean energy production and firm capacity

Greater Northwest

Installed Capacity in 2025 & 2045



+ Meeting 96% GHG Reduction targets in 2045 with mature technologies requires significant scale up of renewables


- 37-49 GW Wind
- 39-54 GW Solar

+ If natural gas allowed to support RA needs, reaching 96% GHG reduction costs ~1 cents/kWh above a no policy case

+ For growing resource adequacy need, up to 24 GW natural gas are selected even in the 96% GHG reduction scenario

- Disallowing no gas in 2045 with 100% GHG reduction requires >250 GW of Battery Storage build out to meet the system reliability requirements
- Meeting increased reliability needs without new gas requires >170 GW of Battery Storage by 2045


GHG reductions up to ~90-95% below 1990 levels can be achieved at or below the social cost of carbon



To meet subregional RA needs, new resources are distributed across the Greater Northwest and new interregional transmission is selected


96% GHG Reduction - High Load Scenario

- Demand Response
- Li-ion Battery
- Solar
- Wind
- Hydro
- Geothermal
- Nuclear
- Natural Gas
- Coal



2025	19,250
2035	21,400 (+2,150)
2045	27,890 (+8,640)



The West of Cascades subregion requires over 4 GW of new firm capacity by 2035 and 17 GW by 2045
Met by ~8 GW local resources and ~9 GW transmission expansion



2025	2,200
2035	2,800 (+1,600)
2045	5,189 (+1,989)

2025	2,400
2035	3,400 (+1,000)
2045	3,719 (+1,319)

The Pacific Northwest subregion requires over 11 GW of new firm capacity by 2035 and 31 GW by 2045
Met by ~28 GW local resources and ~3 GW transmission expansion, which also helps deliver MT+WY wind




As load grows the most West of Cascades, generation grows primarily on the East side and on the rest of the study region

96% GHG Reduction - High Load Scenario

- Demand Response
- Li-ion Battery
- Solar
- Wind
- Hydro
- Geothermal
- Nuclear
- Natural Gas
- Coal

Pacific Northwest West of Cascades Annual Energy (aGW)



Net Imports from East of Cascades


Net Imports from External Zones (CA, BC)

East to West Cascades Tx Interface (aGW)

2025	8.2	←
2035	10.2	←
2045	16.2	←

The West of Cascades subregion requires over 10 aGW of net imports by 2035 and 16 aGW by 2045. Annual Loads of 21 aGW in 2045 are met by less than 5 aGW of local generation.

Pacific Northwest East of Cascades Annual Energy (aGW)



The Pacific Northwest subregion shifts from a net exporter today to a net importer in 2035 and 2045. Direction of flows throughout the year vary substantially based on hydro availability and wind generation levels.


Inland Northwest into Pacific Northwest Tx Interface (aGW)

2025	0.3	←
2035	1.2	←
2045	1.9	←


Central West into Pacific Northwest Tx Interface (aGW)

2025	-0.9	→
2035	-0.4	→
2045	-0.1	→

Inland Northwest Annual Energy (aGW)



Central West Annual Energy (aGW)



Renewable Land Use




Land Use Impact

96% GHG Reduction, Reference Load



Technology	Nameplate MW	Direct land use (acres)	Direct + indirect land use (acres)	Total land use (acres)
Wind ▲	50,790	38,094	4,279,069	4,317,163
Solar ● (utility-scale)	41,470	373,225	n/a	373,225
Total	92,260	411,319	4,279,069	4,690,388



Wind (total project area) = ~85 acres/MW

Solar (direct) = ~9 acres/MW

Wind (permanent direct) = ~0.75 acres/MW


Land Use Impact

96% GHG Reduction, High Load



- Each point on the map indicates 200 MW
- Sites not to scale or indicative of future resource siting locations

Technology	Nameplate MW	Direct land use (acres)	Direct + indirect land use (acres)	Total land use (acres)
Wind ▲	63,485	47,615	5,348,612	5,396,227
Solar ● (utility-scale)	56,899	512,083	n/a	512,083
Total	120,384	559,698	5,348,612	5,908,310



Wind (total project area) = ~85 acres/MW

Solar (direct) = ~9 acres/MW

Wind (permanent direct) = ~0.75 acres/MW


Long-term (2045) System Reliability Dynamics




Long-term Reliability Risk in the Northwest High Loads Scenario under 96% GHG Reduction

- + By 2045, only about 27% of the region's energy comes from hydro, reducing the impact of year-to-year variability, though not eliminating it
- + Under 96% GHG reduction, as much as 70% of generation could come from wind + solar
 - Water variability will continue to be critical for resource adequacy in the region, while renewable variability becomes increasingly important
- + Most simulated shortfall events occur during the cold winter months during high net load *hours* when loads peak and renewables are low
- + Simulated reliability events mostly last less than 12 hours, shorter than the extended duration events modeled for the 2025 system

Average Loss-of-Load Hours (LOLH) by Month x Hour




Distribution of Loss-of-Load Events



Resource availability example: February 2045 (High Loads, 96% GHG Reduction) simulated under 1996 load + 1993 hydro conditions

Greater Northwest in 2045, RECAP simulation of high load, low hydro, but high renewables winter week



Resource availability example: February 2045 (High Loads, 96% GHG Reduction) simulated under 1990 load + 2001 hydro conditions

Greater Northwest in 2045, **RECAP** simulation of shorter-duration reliability risk

